


Model	Disc.	Inlet	A	B	C
S81MB475X6G75A	5" V/c	6" V/c	120.26	14	10.75
S81MB475X7G75A	5" V/c	6" V/c	125.36	14	10.75
S81MB475X8G75A	5" V/c	6" V/c	130.36	14	10.75
S81MB475X8G100A	5" V/c	6" V/c	137.86	14	10.75
S81MB475X9G100A	5" V/c	6" V/c	142.86	14	10.75
S81MB475X10G100A	5" V/c	6" V/c	147.96	14	10.75
S81MB475X10G125A	5" V/c	6" V/c	161.83	14	10.75
S81MB475X11G100A	5" V/c	6" V/c	153.06	14	10.75
S81MB475X11G125A	5" V/c	6" V/c	166.93	14	10.75
S81MB475X12G125A	5" V/c	6" V/c	171.93	14	10.75
S81MB475X12G150A	5" V/c	6" V/c	180.93	14	10.75
S81MB475X13G125A	5" V/c	6" V/c	177.03	14	10.75
S81MB475X13G150A	5" V/c	6" V/c	186.03	14	10.75

CONTACT FACTORY FOR 6 STAGE, 60HP AND BELOW

- NOTES:
1. DIMENSIONS ARE IN INCHES.
 2. PUMP INLET WILL MATE WITH VICTAULIC TYPE CLAMPED UNION. DISCHARGE WILL MATE WITH VICTAULIC TYPE CLAMPED UNION.
 3. DO NOT OPERATE OUTSIDE THE DESIGNATED FLOW RANGE.
 4. 20 PSI MINIMUM INLET PRESSURE IS REQUIRED. PUMP MUST BE COMPLETELY FLOODED BEFORE OPERATING. DO NOT OPERATE PUMP DRY, OPERATING WITH IN THE DESIGNATED FLOW RANGE WILL INSURE ADEQUATE FLOW PAST THE MOTOR FOR COOLING. WATER TEMP NOT TO EXCEED 85°F.
 5. TO ACCOMPLISH CORRECT ROTATION, INTERCHANGE ANY TWO MOTOR LEADS, THEN COMPARE WATER QUANTITY AND DEVELOPED PRESSURE. THE WIRE CONNECTION THAT DEVELOPS THE HIGHEST FLOW AND PRESSURE IS THE CORRECT ONE.
 6. UNIT MUST BE PROPERLY GROUNDED. FAILURE TO DO SO MY RESULT IN SERIOUS ELECTRICAL SHOCK. MOTOR MUST BE GROUNDED IN ACCORDANCE TO NATIONAL AND LOCAL CODES.
 7. REFER TO THE OPERATION AND MAINTNANCE MANUAL FOR ADDITIONAL OPERATIONAL INSTRUCTIONS.
 8. SPECIAL MECHANICAL MODIFICATIONS MAY SUPERSEDE DIMENSIONS WHICH ARE A FUNCTION OF THE MODIFICATION.



1&T Pump Co., Inc. FAIRMONT, WV 26554

<p>DRAWING NO. EMV</p> <p>DESIGNER: EMV</p> <p>CHECKER: EMV</p> <p>DESIGN: EMV</p> <p>ENGINEER: EMV</p>	<p>10-8-24</p> <p>SIZE: A</p> <p>SCALE: A</p>	<p>DRAWING TITLE</p> <p style="font-size: 1.2em; font-weight: bold;">S81MB475 60HZ</p> <p>CAD FILE: S81MB475 CATALOG DWG</p> <p>RELEASE DATE: 4-10-24 SHEET 1 OF 2</p>
--	---	--